

Tony Zircher
Patriot Construction Management

Project: USPS Olympia, WA SDC

Address: 717 76th Avenue SW

Tumwater, WA 98501

This narrative accompanies the release of the Construction Set for this specific project. This narrative does not specifically call out all changes from the 100% Owner Review Set but incorporates items which we feel would significantly impact cost.

These changes include, but are not limited to:

Cover Sheet

TS-001

- Project description for scope of work has been updated.

General Information

N/A

Structural

N/A

Architectural

A-201

- Exterior Elevations have been revised/clarified to show full extent of new work.
- A-402
- Enlarged Plans have been revised/clarified to show full extent of new work.
- A-501
- Additional Casework elevations/ sections have been added to show full extent of new work.

Mechanical

M-001

- Ceiling fan added in Custodian Room 163

M-102

- Ceiling fan added in Custodian Room 163
- Return air has been ducted to the return grilles located in rooms 134, 137, 139, and 162 per code requirements.

Electrical

E-101

- Added (1) type A1 fixture to Men's Restroom 151
- Added (1) type A1 fixture to Women's Restroom 152

E-102

- Added (2) type W6 fixtures to Corridor 133

E-104

- Added (2) type A1 fixtures to Break Room 117
- Added (1) type A1 fixture to Corridor 124

Sincerely,

Christopher Rood

Christopher Rood
Associate Project Manager
GPD Group, Inc.